

TEXAS REAL ESTATE INSPECTOR



Standards of Practice

Texas Real Estate Commission

P. O. Box 12188

Austin, TX 78711-2188

(512) 936-3000

This pocket edition of the SOPs is produced for *information purposes only*. To review the official TREC rules, please see the Chapter 535, Title 22, Texas Administrative Code available at www.sos.texas.gov.

Adopted by the

Texas Real Estate Commission

22 TAC §§535.227 - 535.233

Effective February 1, 2022

TABLE OF CONTENTS

GENERAL PROVISIONS 1

Scope	1
Definitions	3
General Requirements	5
General Limitations	6
Conflicting Provision	9
Departure Provision	10
Enforcement	11

STRUCTURAL SYSTEMS 11

Foundations	11
Grading and Drainage	13
Roof Covering Materials	14
Roof Structures and Attics	15
Interior Walls, Ceilings, Floors, and Doors	16
Exterior Walls, Doors, and Windows	17
Exterior and Interior Glazing	19
Interior and Exterior Stairways	19
Fireplaces and Chimneys	20
Porches, Balconies, Decks, and Carports	21

ELECTRICAL SYSTEMS 22

Service Entrance and Panels	22
Branch Circuits, Connected Devices, and Fixtures	24

NOTES

TABLE OF CONTENTS

NOTES	
HEATING, VENTILATION, AND AIR CONDITIONING SYSTEMS	28
Heating Equipment	28
Cooling Equipment	30
Duct Systems, Chases, and Vents	32
General Limitations (HVAC)	33
PLUMBING SYSTEMS	35
Plumbing Systems	35
Water Heaters	37
Hydro-Massage Therapy Equipment	40
Gas Distribution System	41
APPLIANCES	42
Dishwashers	42
Food Waste Disposers	42
Range Hood and Exhaust Systems	43
Electric or Gas Ranges, Cooktops, & Ovens	43
Microwave Ovens	44
Mechanical Exhaust Systems and Bathroom Heaters	44
Garage Door Operators	45
Dryer Exhaust Systems	45
General Provisions (Appliances)	46

TABLE OF CONTENTS

OPTIONAL COMPONENTS OR SYSTEMS 47

Limitations (Optional Systems)	47
Scope (Optional Systems)	47
Landscape Irrigation (Sprinkler) Systems	47
Swimming Pools, Spas, Hot Tubs, and Equipment	48
Outbuildings	50
Private Water Wells	51
Private Sewage Disposal Systems	52
Other Built-In Appliances	53

(III) site drainage and clearances around or adjacent to the system; and

(IV) the aerobic discharge system.

- (2) The inspector is not required to:
- (A) excavate or uncover the system or its components;
 - (B) determine the size, adequacy, or efficiency of the system; or
 - (C) determine the type of construction used.

OTHER BUILT-IN APPLIANCES

22 TAC §535.233(h)

The inspector shall report deficiencies in condition or operation of other built-in appliances not listed under §535.232 of this title.

(B) determine the reliability of the water supply or source;

or

(C) locate or verify underground water leaks.

GENERAL PROVISIONS

SCOPE

22 TAC §535.227(a)

- (1) These standards of practice apply when a professional inspector or real estate inspector who is licensed under this chapter accepts employment to perform a real estate inspection for a prospective buyer or seller of real property.

- (2) These standards of practice define the minimum requirements for a real estate inspection conducted on a one to four family unit that is substantially completed.
Substantially completed means the stage of construction when a new building, addition, improvement, or alteration to an existing building can be occupied or used for its intended purpose.
- (3) For the purposes of these standards of practice a real estate inspection:
- (A) is a limited visual survey and basic performance evaluation of the systems and components of a building using normal controls that provides information regarding the general condition of a residence at the time of inspection;
- (B) is not intended to be a comprehensive investigation or exploratory probe to determine the cause or effect of deficiencies noted by the inspector; and
- (C) requires the use of reasonable and appropriate tools to satisfy the requirements of the standards of practice.
- (A) report:
- (i) the type of system;
 - (ii) the location of the drain or distribution field; and
 - (iii) the proximity of any known water wells, underground cisterns, water supply lines, bodies of water, sharp slopes or breaks, easement lines, property lines, soil absorption systems, swimming pools, or sprinkler systems; and
- (B) report as Deficient:
- (i) visual or olfactory evidence of effluent seepage or flow at the surface of the ground;
 - (ii) inoperative aerators or dosing pumps; and
 - (iii) deficiencies in:
 - (I) accessible components;
 - (II) functional flow;

However an inspection does not require the use of:

(i) specialized equipment, including but not limited to:

- (I) thermal imaging equipment;
- (II) moisture meters;
- (III) gas or carbon monoxide detection equipment;

(IV) environmental testing equipment and devices;

(V) elevation determination devices;

(VI) ladders capable of reaching surfaces over one story above ground surfaces;

(VII) cameras or other tools used to inspect the interior of a drain or sewer line; or

(VIII)drones; or

(ii) specialized procedures, including but not limited to:

(I) environmental testing;

(II) elevation measurement;

(III) calculations; or

(IV)any method employing destructive testing that damages otherwise sound materials or finishes.

(4) These standards of practice do not prohibit an inspector from providing a higher level of inspection performance than required by these standards of practice or from inspecting components and systems in addition to those listed under

cooling systems that these standards of practice require to be reported for the principal building.

PRIVATE WATER WELLS

22 TAC §535.233(f)

(1) The inspector shall:

(A) operate at least two fixtures simultaneously;
(B) recommend or arrange to have performed coliform testing;

(C) report:

(i) the type of pump and storage equipment;
(ii) the proximity of any known septic system; and

(D) report as Deficient deficiencies in:

- (i) water pressure and flow and performance of pressure switches;
- (ii) the condition of accessible equipment and components; and
- (iii) the well head, including improper site drainage and clearances.

(2) The inspector is not required to:

- (A) open, uncover, or remove the pump, heads, screens, lines, or other components of the system;

- (B) operate valves;
- (C) uncover or excavate any lines or concealed components of the system;
- (D) fill the pool, spa, or hot tub with water;
- (E) inspect any system that has been winterized, shut down, or otherwise secured;

(F) determine the presence of sub-surface water tables;

(G) determine the effectiveness of entrapment covers;

(H) determine the presence of pool shell or sub-surface leaks; or

(I) inspect ancillary equipment such as computer controls, covers, chlorinators or other chemical dispensers, or water ionization devices or conditioners other than required by this section.

DEFINITIONS

22 TAC §535.227(b)

- (1) **Accessible**--In the reasonable judgment of the inspector, capable of being approached, entered, or viewed without:
 - (A) hazard to the inspector;
 - (B) having to climb over obstacles, moving furnishings or large, heavy, or fragile objects;
 - (C) using specialized equipment or procedures;
 - (D) disassembling items other than covers or panels intended to be removed for inspection;
 - (E) damaging property, permanent construction or building finish; or
 - (F) using a ladder for portions of the inspection other than the roof or attic space.
- (2) **Chapter 1102**--Texas Occupations Code, Chapter 1102.
- (3) **Component**--A part of a system.
- (4) **Cosmetic**--Related only to appearance or aesthetics, and

the standards of practice. If an inspector provides services beyond the scope required by these standards of practice, including the use of specialized equipment, or inspects components and systems in addition to those listed under the standards of practice, the inspector must possess the competency required to do so.

OUTBUILDINGS

22 TAC §535.233(e)

- (1) The inspector shall report as Deficient the absence or failure in performance of ground-fault circuit interrupter protection devices in grade-level portions of unfinished accessory buildings used for storage or work areas, boathouses, and boat hoists; and
- (2) The inspector shall report as Deficient deficiencies in the structural, electrical, plumbing, heating, ventilation, and

not related to performance, operability, or water penetration.

(5) **Deficiency**--In the reasonable judgment of the inspector, a condition that:

(A) adversely and materially affects the performance of a system, or component; or
(B) constitutes a hazard to life, limb, or property as specified by these standards of practice.

(6) **Deficient**--Reported as having one or more deficiencies.

(7) **Gas distribution system**--All gas lines between the point of delivery and appliance shutoff valves.

(A) The point of delivery for a natural gas system is:

- (i) the outlet of the service meter assembly;
- (ii) the outlet of the service regulator; or
- (iii) the service shut valve where a meter is not provided.
Where a system shutoff valve is provided after the outlet of the service meter assembly, such valve shall be considered to be downstream of the point of delivery.

(B) The point of delivery for undiluted liquefied petroleum gas systems is the outlet of the service pressure regulator, exclusive of line gas regulators, in the system.

(8) **Inspect**--To operate in normal ranges using ordinary controls at typical settings, look at and examine accessible

(B) report as Deficient:

- (i) the presence of a single blockable main drain (potential entrapment hazard);
 - (ii) a pump motor, blower, or other electrical equipment that lacks bonding;
 - (iii) the absence of or deficiencies in safety barriers;
 - (iv) water leaks in above-ground pipes and equipment;
 - (v) the absence or failure in performance of ground-fault circuit interrupter protection devices; and
 - (vi) deficiencies in:
 - (I) surfaces;
 - (II) tiles, coping, and decks;
 - (III) slides, steps, diving boards, handrails, and other equipment;
 - (IV) drains, skimmers, and valves;
 - (V) filters, gauges, pumps, motors, controls, and sweeps;
 - (VI) lighting fixtures; and
 - (VII) the pool heater that these standards of practice require to be reported for the heating system.
- (2) The inspector is not required to:
- (A) disassemble filters or dismantle or otherwise open any components or lines;

- (iv) the absence of a backflow prevention device;
- (v) the absence of shutoff valves between the water meter and backflow device;
- (vi) deficiencies in the performance and mounting of the controller;

- (vii) missing or damaged components; and
- (viii) deficiencies in the performance of the water emission devices; such as, sprayer heads, rotary sprinkler heads, bubblers or drip lines.

(2) The inspector is not required to inspect:

- (A) for effective coverage of the irrigation system;
- (B) the automatic function of the controller;
- (C) the effectiveness of the sensors; such as, rain, moisture, wind, flow or freeze sensors;
- (D) sizing and effectiveness of backflow prevention device; or
- (E) report on the performance of an underground zone.

systems or components and report observed deficiencies as specified by these standards of practice.

- (9) **Performance**--Achievement of an operation, function or configuration relative to accepted industry standard practices with consideration of age and normal wear and tear from ordinary use.

- (10) **Report**--To provide the inspector's opinions and findings regarding systems and components required by the standards of practice.
- (11) **Standards of Practice**--§§535.227 - 535.233 of this title.

GENERAL REQUIREMENTS

22 TAC §535.227(c)

The inspector shall:

- (1) operate fixed or installed equipment and appliances listed herein in at least one mode with ordinary controls at typical settings;
- (2) visually inspect accessible systems or components from near proximity to the systems and components, and from the interior of the attic and crawl spaces; and
- (3) complete the standard inspection report form as required by §535.222 and §535.223 of this title.

SWIMMING POOLS, SPAS, HOT TUBS, AND EQUIPMENT

22 TAC §535.233(d)

(1) The inspector shall:

- (A) report the type of construction;

GENERAL LIMITATIONS

22 TAC §535.227(d)

The inspector is not required to:

(1) inspect;

(A) items other than those listed within these standards of practice;

(B) elevators;

(C) detached buildings, decks, docks, fences, waterfront structures, or related equipment;

(D) anything buried, hidden, latent, or concealed;

(E) sub-surface drainage systems;

(F) automated or programmable control systems, automatic shutoff, photoelectric sensors, timers, clocks, metering devices, signal lights, lightning arrestor system, remote controls, security or data distribution systems, solar panels or smart home automation components; or

(G) concrete flatwork such as driveways, sidewalks, walkways, paving stones or patios;

(2) report;

(A) past repairs that appear to be effective and workmanlike except as specifically required by these standards;

(B) cosmetic or aesthetic conditions; or

(C) wear and tear from ordinary use;

OPTIONAL COMPONENTS OR SYSTEMS

LIMITATIONS (OPTIONAL SYSTEMS)

22 TAC §535.233(a)

An inspector is not required to inspect the components or systems described under this section.

SCOPE (OPTIONAL SYSTEMS)

22 TAC §535.233(b)

If an inspector agrees to inspect a component or system described under this section, the general provisions under §535.227 of this title and the provisions and requirements of this section applicable to that component or system apply.

LANDSCAPE IRRIGATION (SPRINKLER) SYSTEMS

22 TAC §535.233(c)

(1) The inspector shall:

(A) manually operate all zones or stations on the system through the controller;

(B) report as Deficient:

(i) the absence of a rain or moisture sensor;

(ii) inoperative zone valves;

(iii) surface water leaks;

- (2) the absence of a dryer exhaust system when provisions are present for a dryer;
- (3) ducts that do not terminate to the outside of the building;
- (4) screened terminations; and
- (5) ducts that are not made of metal with a smooth interior finish.
-

(3) determine:

- (A) the presence or absence of pests, termites, or other wood-destroying insects or organisms;
- (B) the presence, absence, or risk of:
 - (i) asbestos;
 - (ii) lead-based paint;
 - (iii) mold, mildew;
 - (iv) corrosive or contaminated drywall "Chinese Drywall"; or
 - (v) any other environmental hazard, environmental pathogen, carcinogen, toxin, mycotoxin, pollutant, fungal presence or activity, or poison;
- (C) types of wood or preservative treatment and fastener compatibility;
- (D) the cause or source of a condition;
- (E) the cause or effect of deficiencies; or
- (F) any of the following issues concerning a system or component:
 - (i) insurability or warrantability;
 - (ii) suitability, adequacy, compatibility, capacity, reliability, marketability, or operating costs;
 - (iii) recalls, counterfeit products, or product lawsuits;
 - (iv) life expectancy or age;

GENERAL PROVISIONS (APPLIANCES)

22 TAC §535.232(i)

The inspector is not required to:

- (1) operate or determine the condition of other auxiliary components of inspected items;
- (2) test for microwave oven radiation leaks;
- (3) inspect self-cleaning functions;
- (4) disassemble appliances;
- (5) determine the adequacy of venting systems;
- (6) determine proper routing and lengths of duct systems;
- (7) operate or determine the condition of clothes washer, clothes dryer, or refrigerator; or
- (8) operate or determine the condition of other built-in appliances, except as provided for under §535.233(h), of this title.

- (v) energy efficiency, vapor barriers, or thermostatic performance;
- (vi) compliance with any code, listing, testing or protocol authority;
- (vii) utility sources; or

(viii) manufacturer or regulatory requirements, except as specifically required by these standards;

(4) anticipate future events or conditions, including but not limited to:

- (A) decay, deterioration, or damage that may occur after the inspection;
- (B) deficiencies from abuse, misuse or lack of use;
- (C) changes in performance of any component or system due to changes in use or occupancy;
- (D) the consequences of the inspection or its effects on current or future buyers and sellers;
- (E) common household accidents, personal injury, or death;
- (F) the presence of water penetrations; or
- (G) future performance of any item;

(5) operate shutoff, safety, stop, pressure or pressure-regulating valves or items requiring the use of codes, keys, combinations, or similar devices;

(4) missing or damaged components;

(5) ducts that do not terminate outside the building; and

(6) a gas heater that is not vented to the exterior of the building unless the unit is listed as an unvented type.

GARAGE DOOR OPERATORS

22 TAC §535.232(g)

The inspector shall report as Deficient:

- (1) inoperative units;
- (2) deficiencies in performance or mounting;
- (3) missing or damaged components;
- (4) installed photoelectric sensors located more than six inches above the garage floor;
- (5) deficiencies in performance or absence of auto reversing mechanisms and manual detachment device; and
- (6) door locks or side ropes that have not been removed or disabled.

DRYER EXHAUST SYSTEMS

22 TAC §535.232(h)

The inspector shall report as Deficient:

- (1) missing or damaged components;

- (4) absence of an anti-tip device, if applicable;
- (5) gas leaks in the gas range, cooktops and ovens not associated with the gas distribution system; and

(6) deficiencies in:

- (A) thermostat accuracy (within 25 degrees Farenheit at a setting of 350 degrees Farenheit); and

(B) mounting and performance.

(6) designate conditions as safe;

- (7) recommend or provide engineering, architectural, appraisal, mitigation, physical surveying, realty, or other specialist services;
- (8) review historical records, installation instructions, repair plans, cost estimates, disclosure documents, or other reports;
- (9) verify sizing, efficiency, or adequacy of the ground surface drainage system;
- (10) verify sizing, efficiency, or adequacy of the gutter and downspout system;
- (11) operate recirculation or sump pumps;
- (12) remedy conditions preventing inspection of any item;
- (13) apply open flame or light a pilot to operate any appliance;
- (14) turn on decommissioned equipment, systems or utility services; or

- (15) provide repair cost estimates, recommendations, or re-inspection services.

CONFLICTING PROVISION

22 TAC §535.227(e)

In the event of a conflict between the general provisions set out in this section, and the specific provisions specified elsewhere in

the standards of practice, specific provisions shall take precedence.

DEPARTURE PROVISION

22 TAC §535.227(f)

(1) An inspector may depart from the inspection of a component or system required by the standards of practice only if:

(A) the inspector and client agree the item is not to be inspected;

(B) the inspector is not qualified to inspect the item;

(C) in the reasonable judgment of the inspector, the inspector determines that:

- (i) conditions exist that prevent inspection of an item;
- (ii) conditions or materials are hazardous to the health or safety of the inspector; or

(iii) the actions of the inspector may cause damage to the property; or

(D) the item is a common element of a multi-family development and is not in physical contact with the unit being inspected, such as the foundation under another building or a part of the foundation under another unit in the same building.

(2) If an inspector departs from the inspection of a component or system required by the standards of practice, the

(1) inoperative units;

(2) deficiencies in performance or mounting;

(3) missing or damaged components; and

(4) the presence of visible active water leaks.

RANGE HOODS AND EXHAUST SYSTEMS

22 TAC §535.232(c)

The inspector shall report as Deficient:

- (1) inoperative units;
- (2) deficiencies in performance or mounting;
- (3) missing or damaged components;
- (4) ducts that do not terminate outside the building, if the unit is not of a re-circulating type or configuration; and
- (5) improper duct material.

ELECTRIC OR GAS RANGES, COOKTOPS, AND OVENS

22 TAC §535.232(d)

The inspector shall report as Deficient:

- (1) inoperative units;
- (2) missing or damaged components;
- (3) combustible material within thirty inches above the cook top burners;

(vi) lack of visible bonding on gas distribution system, including corrugated stainless steel tubing (CSST); and

(vii) lack of visible sediment traps.

(2) Specific limitation for gas lines. The inspector is not required to:

- (A) inspect sacrificial anode bonding or for its existence;
- (B) pressurize or test gas system, drip legs or shutoff valves;
- (C) operate gas line shutoff valves; or
- (D) light or ignite pilot flames.

APPLIANCES

DISHWASHERS

22 TAC §535.232(a)

The inspector shall report as Deficient:

- (1) inoperative units;
- (2) deficiencies in performance or mounting;
- (3) rusted, missing or damaged components;
- (4) the presence of visible active water leaks; and
- (5) the absence of visible backflow prevention.

FOOD WASTE DISPOSERS

22 TAC §535.232(b)

The inspector shall report as Deficient:

inspector shall:

- (A) notify the client at the earliest practical opportunity that the component or system will not be inspected; and
- (B) make an appropriate notation on the inspection report form, stating the reason the component or system was not inspected.
- (3) If the inspector routinely departs from inspection of a component or system required by the standards of practice, and the inspector has reason to believe that the property being inspected includes that component or system, the inspector shall not perform the inspection of the property until the inspector notifies the client, or the prospective client, that the component or system will not be inspected.

ENFORCEMENT

22 TAC §535.227(g)

Failure to comply with the standards of practice is grounds for disciplinary action as prescribed by Chapter 1102.

STRUCTURAL SYSTEMS

FOUNDATIONS

22 TAC §535.228(a)

- (1) The inspector shall:
 - (A) render a written opinion as to the performance of the foundation;

GAS DISTRIBUTION SYSTEM

22 TAC §535.231(d)

- GAS DISTRIBUTION SYSTEM**

22 TAC §5535.231(d)

(1) The inspector shall:

(A) report:

(i) location of gas meter; and

(ii) visible material used for gas distribution system;

(B) report as Deficient:

(i) noticeable gas leaks;

(ii) the absence of a gas shutoff valve within six feet of the appliance;

(iii) the absence of a gas appliance connector or one that exceeds six feet in length;

(iv) gas appliance connectors that are concealed within or extended through walls, floors, partitions, ceilings or appliance housings;

(v) deficiencies in:

(I) gas shutoff valves;

(II) access to a gas shutoff valves that prohibits full operation;

(III) gas appliance connector materials; and

(IV) the condition and type of gas distribution lines and fittings;

(C) generally report present and visible indications used to render the opinion of adverse performance, such as:

(i) binding, out-of-square, non-latching doors;

(ii) framing or frieze board separations;

(iii) sloping floors;

(iv) window, wall, floor, or ceiling cracks or separations; and

(v) rotating, buckling, cracking, or deflecting masonry cladding; and

(D) report as Deficient:

(i) deteriorated materials;

(ii) deficiencies in foundation components such as; beams, joists, bridging, blocking, piers, posts, pilings, columns, sills or subfloor;

(iii) deficiencies in retaining walls related to foundation performance;

(iv) exposed or damaged reinforcement;

(v) crawl space ventilation that is not performing; and

(B) flame impingement, uplifting flame, improper flame color, or excessive scale build-up; and

(C) deficiencies in:

- (i) combustion and dilution air; and
- (ii) vent pipe, draft hood, draft, proximity to combustibles, and vent termination point and clearances.

(vi) crawl space drainage that is not performing.

(2) The inspector is not required to:

- (A) enter a crawl space or any area where headroom is less than 18 inches or the access opening is less than 24 inches wide and 18 inches high;
- (B) provide an exhaustive list of indicators of possible adverse performance; or
- (C) inspect retaining walls not related to foundation performance.

HYDRO-MASSAGE THERAPY EQUIPMENT

22 TAC §535.231(c)

(1) The inspector shall report as Deficient:

- (A) inoperative units;
- (B) the presence of active leaks;
- (C) deficiencies in components and performance;
- (D) missing and damaged components;
- (E) the absence of an opening that would allow access to equipment for inspection, service, repair or replacement without removing permanent construction or building finish; and
- (F) the absence or failure of operation of ground-fault circuit interrupter protection devices.

(2) The inspector is not required to determine the adequacy of self-draining features of circulation systems.

- (A) inspect flatwork or detention/retention ponds (except as related to slope and drainage);
- (B) determine area hydrology or the presence of underground water; or
- (C) determine the efficiency or performance of underground or surface drainage systems.

ROOF COVERING MATERIALS

22 TAC §535.228(c)

(1) The inspector shall:

(A) inspect the roof covering materials from the surface of the roof;

(B) report:

(i) type of roof coverings;

(ii) vantage point from where the roof was inspected;

(iii) evidence of water penetration; and

(iv) evidence of previous repairs to the roof covering material, flashing details, skylights and other roof penetrations; and

(C) report as Deficient deficiencies in:

(i) fasteners;

(ii) adhesion;

(iii) roof covering materials;

(iv) flashing details;

(v) skylights; and

(vi) other roof penetrations.

(2) The inspector is not required to:

- (A) inspect the roof from the roof level if, in the inspector's reasonable judgment:
- (XI) the absence of or visible deficiencies in the temperature and pressure relief valve and discharge piping; and
- (XII) a temperature and pressure relief valve that failed to operate, when tested manually.
- (B) The inspector is not required to:
- (i) verify the effectiveness of the temperature and pressure relief valve, discharge piping, or pan drain pipes;
- (ii) operate the temperature and pressure relief valve if the operation of the valve may, in the inspector's reasonable judgment, cause damage to persons or property; or
- (iii) determine the efficiency or adequacy of the unit.
- (2) Requirements for electric units. The inspector shall report as Deficient deficiencies in:
- (A) performance of heating elements; and
- (B) condition of conductors; and
- (3) Requirements for gas units. The inspector shall report as Deficient:
- (A) gas leaks in water heater not associated with the gas distribution system;

platform that would allow access for equipment inspection, service, repair or replacement;

(XI) the absence of or visible deficiencies in the temperature and pressure relief valve and discharge piping; and

(XII) a temperature and pressure relief valve that failed to operate, when tested manually.

(B) The inspector is not required to:

- (i) verify the effectiveness of the temperature and pressure relief valve, discharge piping, or pan drain pipes;
- (ii) operate the temperature and pressure relief valve if the operation of the valve may, in the inspector's reasonable judgment, cause damage to persons or property; or
- (iii) determine the efficiency or adequacy of the unit.

(2) Requirements for electric units. The inspector shall report as Deficient deficiencies in:

(A) performance of heating elements; and

(B) condition of conductors; and

- (3) Requirements for gas units. The inspector shall report as Deficient:
- (A) gas leaks in water heater not associated with the gas distribution system;

- (I) the energy source;
- (II) the capacity of the units;
- (ii) report as Deficient:
- (I) inoperative units;
- (II) leaking or corroded fittings or tanks;
- (III) damaged or missing components;
- (IV)the absence of a cold water shutoff valve;
- (V) if applicable, the absence of a pan or a pan drain system that does not terminate over a waste receptor or to the exterior of the building above the ground surface;
- (VI)inappropriate locations;
- (VII)the lack of protection from physical damage;
- (VIII)burners, burner ignition devices or heating elements, switches, or thermostats that are not a minimum of 18 inches above the lowest garage floor elevation, unless the unit is listed for garage floor installation;
- (IX)the absence of an opening that would allow access to equipment for inspection, service, repair or replacement without removing permanent construction or building finish;
- (X)when applicable; a floored passageway and service
- (i) the inspector cannot safely reach or stay on the roof;
or
(ii) significant damage to the roof covering materials may result from walking on the roof;
- (B) determine:
- (i) the remaining life expectancy of the roof covering; or
(ii) the number of layers of roof covering material;
- (C) identify latent hail damage;
- (D) exhaustively examine all fasteners and adhesion; or
- (E) provide an exhaustive list of locations of deficiencies and water penetrations.
-
- ## ROOF STRUCTURES AND ATTICS
- 22 TAC §535.228(d)**
- (1) The inspector shall:
- (A) report:
- (i) the vantage point from which the attic space was inspected;
- (ii) approximate average depth of attic insulation; and
(iii) evidence of water penetration;
- (B) report as Deficient:
- (i) attic space ventilation that is not performing;

- (ii) deflections or depressions in the roof surface as related to adverse performance of the framing and decking; and

(iii) missing insulation; and

- (iv) deficiencies in:
- (I) installed framing members and decking;
 - (II) attic access ladders and access openings; and
 - (III) attic ventilators.

(2) The inspector is not required to:

- (A) enter attics or unfinished spaces where openings are less than 22 inches by 30 inches or headroom is less than 30 inches;

(B) operate powered ventilators; or

(C) provide an exhaustive list of locations of deficiencies and water penetrations.

(D) inspect:

- (i) any system that has been winterized, shut down or otherwise secured;

- (ii) circulating pumps, free-standing appliances, solar water heating systems, water-conditioning equipment, filter systems, water mains, private water supply systems, water wells, pressure tanks, sprinkler systems, swimming pools, or fire sprinkler systems;
- (iii) inaccessible gas supply system components for leaks;
- (iv) for sewer clean-outs; or
- (v) for the presence or performance of private sewage disposal systems; or

(E) determine:

- (i) quality, potability, or volume of the water supply; or
- (ii) effectiveness of backflow or anti-siphon devices.

INTERIOR WALLS, CEILINGS, FLOORS, AND DOORS

22 TAC §535.228(e)

(1) The inspector shall:

(A) report evidence of water penetration; and

(B) report as Deficient:

- (i) deficiencies in the condition and performance of doors and hardware;

WATER HEATERS

22 TAC §535.231(b)

(1) General Requirements.

(A) The inspector shall:

- (i) report;

- (III) back-flow devices, anti-siphon devices, or air gaps at the flow end of fixtures; and
- (vi) deficiencies in:
 - (I) water supply pipes and waste pipes;
 - (II) the installation and termination of the vent system;
 - (III) the performance of fixtures and faucets not connected to an appliance;
 - (IV) water supply, as determined by viewing functional flow in two fixtures operated simultaneously;
 - (V) fixture drain performance;
 - (VI) orientation of hot and cold faucets
- (VII) installed mechanical drain stops;
- (VIII) commodes, fixtures, showers, tubs, and enclosures; and
- (IX) the condition of the gas distribution system.

(2) The inspector is not required to:

- (A) operate any main, branch, or shut-off valves;
- (B) operate or inspect sump pumps or waste ejector pumps;
- (C) verify the performance of:
 - (i) the bathtub overflow;

EXTERIOR WALLS, DOORS, AND WINDOWS

22 TAC §535.228(f)

- (1) The inspector shall:
 - (A) report evidence of water penetration; and
 - (B) report as Deficient:
- (2) The inspector is not required to:
 - (i) the absence of performing emergency escape and rescue openings in all sleeping rooms;
 - (ii) an attached garage doorway that is not equipped with self-closing or automatic closing devices;
 - (iii) a door between the residence and an attached garage that is:
 - (I) a solid wood door less than 1-3/8 inches thick;

(II) a solid honeycomb core steel door less than 1-3/8 inches thick; or

(III) not a 20-minute fire-rated door;

(iv) missing or damaged screens;

(v) deficiencies related to structural performance or water penetration; and

(vi) deficiencies in:

(I) weather stripping, gaskets or other air barrier materials;

(II) claddings;

(III) water resistant materials and coatings;

(IV) flashing details and terminations;

(V) the condition and performance of exterior doors, garage doors and hardware; and

(VI) the condition and performance of windows and components.

(2) The inspector is not required to:

(A) report the condition of awnings, blinds, shutters, security devices, or other non-structural systems;

(B) determine the cosmetic condition of paints, stains, or other surface coatings;

(C) operate a lock if the key is not available; or

PLUMBING SYSTEMS

PLUMBING SYSTEMS

22 TAC §535.231(a)

(1) The inspector shall:

(A) report:

- (i) location of water meter;
- (ii) location of homeowners main water supply shutoff valve; and
- (iii) static water pressure;
- (iv) visible material used for water supply lines and drain lines;

(B) report as Deficient:

- (i) the presence of active leaks;
- (ii) water pressure exceeding 80 PSI;
- (iii) the lack of a pressure reducing valve when the water pressure exceeds 80 PSI;
- (iv) the lack of a visible expansion tank when a pressure reducing valve, check valve, or backflow preventer is in place at the water supply line/system;
- (v) the absence of:
 - (I) fixture shutoff valves;
 - (II) dielectric unions, when applicable;

- (3) operate:
- (A) setback features on thermostats or controls;
 - (B) radiant heaters, steam heat systems, or unvented gas-fired heating appliances; or
 - (C) cooling or heating systems when weather conditions or other circumstances may cause equipment damage, including:
 - (i) cooling equipment when the outdoor temperature is less than 60 degrees Fahrenheit; and
 - (ii) heat pumps, in the heat pump mode, when the outdoor temperature is above 70 degrees Fahrenheit;

(4) verify:

- (A) compatibility of components;

(B) tonnage and manufacturer match of indoor coils and outside coils or condensing units;

(C) the accuracy of thermostats; or

(D) the integrity of the heat exchanger; or

(5) determine:

- (A) sizing, efficiency, or adequacy of the system;

(B) balanced air flow of the conditioned air to the various parts of the building; or

(C) types of materials contained in insulation.

- (D) provide an exhaustive list of locations of deficiencies and water penetrations.

EXTERIOR AND INTERIOR GLAZING

22 TAC §535.228(g)

- (1) The inspector shall report as Deficient:
- (A) insulated windows that are obviously fogged or display other evidence of broken seals;
 - (B) deficiencies in glazing, weather stripping and glazing compound in windows and doors;
 - (C) the absence of safety glass in hazardous locations; and
 - (D) the absence of fall protection at windows that are located less than 24 inches from the finished floor and greater than 72 inches from the finished grade.
- (2) The inspector is not required to:
- (A) exhaustively inspect insulated windows for evidence of broken seals;
 - (B) exhaustively inspect glazing for identifying labels; or
 - (C) identify specific locations of damage.

INTERIOR AND EXTERIOR STAIRWAYS

22 TAC §535.228(h)

- (1) The inspector shall report as Deficient:

- (A) spacing between intermediate balusters, spindles, or rails for steps, stairways, guards, and railings that permit passage of an object greater than 4 inches in diameter, except that on the open side of the staircase treads, spheres less than 4-3/8 inches in diameter may pass through the guard rail balusters or spindles; and
- (B) deficiencies in steps, stairways, landings, guardrails, and handrails.
- (2) The inspector is not required to exhaustively measure every stairway component.

- (C) the absence of air flow at accessible supply registers;
- (D) the presence of gas piping and sewer vents concealed in ducts, plenums and chases;
- (E) ducts or plenums in contact with earth; and
- (F) deficiencies in:
- (i) filters;
 - (ii) grills or registers; and
 - (iii) the location of return air openings.

FIREPLACES AND CHIMNEYS

22 TAC §535.228(i)

(1) The inspector shall report as Deficient:

- (A) built-up creosote in accessible areas of the firebox and flue;
- (B) the presence of combustible materials in near proximity to the firebox opening;
- (C) the absence of fireblocking at the attic penetration of the chimney flue, where accessible; and
- (D) deficiencies in the:
- (i) damper;
 - (ii) lintel, hearth, hearth extension, and firebox;
 - (iii) gas fixture installed in the fireplace not associated with the gas distribution system;

GENERAL LIMITATIONS (HVAC)

22 TAC §535.230(d)

For heating, ventilation, and air conditioning systems inspected under this section, the inspector is not required to perform the following actions:

- (1) program digital thermostats or controls;
- (2) inspect:
 - (A) for pressure of the system refrigerant, type of refrigerant, or refrigerant leaks;
 - (B) winterized or decommissioned equipment; or
 - (C) duct fans, humidifiers, dehumidifiers, air purifiers, motorized dampers, electronic air filters, multi-stage controllers, sequencers, heat reclaimers, wood burning stoves, boilers, oil-fired units, supplemental heating appliances, de-icing provisions, or reversing valves;

- (I) the condensate drain and auxiliary/secondary pan and drain system;
- (II) mounting and performance of window or wall units; and
- (III) thermostats.
- (2) Requirements for evaporative coolers.
- (A) the inspector shall report:
- (i) type of systems; and
 - (ii) the type of water supply line; and
- (B) the inspector shall report as Deficient:
- (i) inoperative units;
 - (ii) inadequate access and clearances;
 - (iii) deficiencies in performance or mounting;
 - (iv) missing or damaged components;
 - (v) the presence of active water leaks; and
 - (vi) the absence of backflow prevention.
-
- PORCHES, BALCONIES, DECKS, AND CARPORTS**
- 22 TAC §535.228(j)**
- (1) The inspector shall:
- (A) inspect:
- (i) attached balconies, carports, and porches; and
 - (ii) abutting porches, decks, and balconies that are used for ingress and egress; and
- (B) report as Deficient:
- (i) on decks 30 inches or higher above the adjacent grade, spacings between intermediate balusters, spindles, or rails that permit passage of an object greater than four inches in diameter; and
 - (ii) deficiencies in accessible components.
-
- DUCT SYSTEMS, CHASES, AND VENTS**
- 22 TAC §535.230(c)**
- (1) the inspector shall report as Deficient:
- (A) damaged duct systems or improper material;
 - (B) damaged or missing duct insulation;
- (2) The inspector is not required to:

- (A) exhaustively measure every porch, balcony, deck, or attached carport components; or
- (B) enter any area where headroom is less than 18 inches or the access opening is less than 24 inches wide and 18 inches high.

ELECTRICAL SYSTEMS

SERVICE ENTRANCE AND PANELS

22 TAC §535.229(a)

(1) The inspector shall report as Deficient:

(A) a drop, weatherhead or mast that is not securely fastened to the building;

(B) the absence of or deficiencies in the grounding electrode system;

(C) missing or damaged dead fronts or covers plates;

(D) conductors not protected from the edges of electrical cabinets, gutters, or cutout boxes;

(E) electrical cabinets and panel boards not appropriate for their location; such as a clothes closet, bathrooms or where they are exposed to physical damage;

(F) electrical cabinets and panel boards that are not accessible or do not have a minimum of 36-inches of clearance in front of them;

(G) deficiencies in:

- (i) inoperative units;
 - (ii) deficiencies in the performance of the cooling system
- (B) enter any area where headroom is less than 18 inches or the access opening is less than 24 inches wide and 18 inches high.
- (I) fails to achieve a 15 degrees Fahrenheit to 22 degrees Fahrenheit temperature differential; or
 - (II) fails to cool adequately as determined by other industry-accepted methods;
- (iii) the absence of an opening that would allow access to equipment for inspection, service, repair or replacement without removing permanent construction or building finish;
- (iv) when applicable; a floored passageway and service platform that would allow access for equipment inspection, service, repair or replacement;
- (v) noticeable vibration of blowers or fans;
- (vi) water in the auxiliary/secondary drain pan;
- (vii)a primary drain pipe that discharges in a sewer vent;
- (viii)missing or deficient refrigerant pipe insulation;
- (ix)dirty coils, where accessible;
- (x) condensing units lacking adequate clearances or air circulation or that has deficiencies in the fins, location, levelness, or elevation above grade surfaces; and
- (xi) deficiencies in:

- (i) electrical cabinets, gutters, cutout boxes, and panel

the gas distribution system;

(B) flame impingement, uplifting flame, improper flame color, or excessive scale buildup; and

(C) deficiencies in:

- (i) combustion, and dilution air; and
 - (ii) the vent pipe, draft hood, draft, proximity to combustibles, and vent termination point and clearances.
-

boards;

- (ii) the insulation of the service entrance conductors, drip loop, separation of conductors at weatherheads, and clearances;

(iii) the compatibility of overcurrent devices and conductors;

- (iv) the overcurrent device and circuit for labeled and listed 250 volt appliances;

(v) bonding and grounding;

COOLING EQUIPMENT

22 TAC §535.230(b)

(1) Requirements for cooling units other than evaporative coolers.

(A) the inspector shall:

- (i) report the type of systems;
- (ii) measure and report the temperature difference between the supply air and the returned air or report industry-accepted method used to determine performance; and
- (iii) generally report extraneous factors or conditions, present on the day of the inspection, that would adversely impact the temperature differential of an otherwise performing unit; and

(B) the inspector shall report as Deficient:

- (2) The inspector is not required to:
 - (A) determine present or future sufficiency of service capacity amperage, voltage, or the capacity of the electrical system;
 - (B) the inspector shall report as Deficient:

- (B) conduct voltage drop calculations;
- (C) determine the accuracy of overcurrent device labeling;
- (D) remove covers where hazardous as judged by the inspector;
- (E) verify the effectiveness of overcurrent devices; or
- (F) operate overcurrent devices.

BRANCH CIRCUITS, CONNECTED DEVICES, AND FIXTURES

22 TAC §535.229(b)

(1) The inspector shall:

- (A) manually test the installed and accessible smoke and carbon monoxide alarms;

- (B) report the type of branch circuit conductors; and

(C) report as Deficient:

- (i) the absence of ground-fault circuit interrupter protection in all:
 - (I) bathroom receptacles;
 - (II) garage and accessory building receptacles;
 - (III) outdoor receptacles;
 - (IV) crawl space receptacles and lighting outlets;
 - (V) basement receptacles;
- (2) Requirements for electric units. The inspector shall report deficiencies in:
 - (A) performance of heat pumps;
 - (B) performance of heating elements; and
 - (C) condition of conductors; and
- (3) Requirements for gas units. The inspector shall report as Deficient:
 - (A) gas leaks in the heating equipment not associated with

- (B) disassemble mechanical appliances;
 - (C) verify the effectiveness of smoke alarms;
 - (D) verify interconnectivity of smoke alarms;
 - (E) activate smoke or carbon monoxide alarms that are or may be monitored or require the use of codes;
 - (F) verify that smoke alarms are suitable for the hearing-impaired;
 - (G) remove the covers of junction, fixture, receptacle or switch boxes unless specifically required by these standards; or
 - (H) test arc-fault circuit interrupter devices when the property is occupied or damage to personal property may result, in the inspector's reasonable judgment.
- HEATING, VENTILATION, AND AIR CONDITIONING SYSTEMS**
- HEATING EQUIPMENT**
 - 22 TAC §535.230(a)**
 - (1) General requirements. The inspector shall:
 - (A) report:
 - (i) the type of heating systems; and
 - (ii) the energy sources; and
 - (B) report as Deficient:
 - (i) inoperative units;
 - (V) receptacles that serve kitchen countertops;
 - (VI) receptacles that are located within six feet of the outside edge of a sink, shower, or bathtub;
 - (VII) laundry area receptacles;
 - (VIII) indoor damp and wet location receptacles;
 - (IX) kitchen dishwasher receptacle; and
 - (X) electrically heated floors;
 - (XI) the absence of arc-fault protection in the following locations:
 - (I) kitchens;
 - (II) family rooms;
 - (III) dining rooms;
 - (IV) living rooms;
 - (V) parlors;
 - (VI) libraries;
 - (VII) dens;
 - (VIII) bedrooms;
 - (IX) sunrooms;
 - (X) recreation rooms;
 - (XI) closets;
 - (XII) hallways; and

- (XIII) laundry area;
- (iii) the failure of operation of ground-fault circuit interrupter protection devices;
- (iv) missing or damaged receptacle, switch or junction box covers;
- (v) the absence of:
- (I) equipment disconnects; and
 - (II) appropriate connections, such as copper/ aluminum approved devices, if branch circuit aluminum conductors are discovered in the main or sub-panel based on a random sampling of accessible receptacles and switches;
- (vi) receptacles less than five and a half feet above the floor that are not tamper resistant;
- (vii) deficiencies in 125 volt receptacles by determining the:
- (I) presence of power;
 - (II) correct polarity; and
 - (III) presence of grounding;
- (viii) deficiencies in 250 volt receptacles by determining the presence of power;
- (ix) deficiencies in
- (I) switches;
- (2) The inspector is not required to:
- (A) inspect low voltage wiring;
- (I) bonding or grounding;
- (III) wiring, wiring terminations, junction boxes, devices, and fixtures, including improper location;
- (IV) doorbell and chime components; and
- (V) smoke and carbon monoxide alarms;
- (x) improper use of extension cords;
- (xi) deficiencies in or absences of conduit, where applicable;
- (xii) the absence of smoke alarms;
- (I) in each sleeping room;
- (II) outside each separate sleeping area in the immediate vicinity of the sleeping rooms; and
- (III) in the living space of each story of the dwelling; and
- (xiii) the absence of carbon monoxide alarms outside each separate sleeping area in the immediate vicinity of the sleeping rooms when either of the following conditions exist:
- (I) fuel fired appliance are installed in the dwelling; or
 - (II) an attached garage with an opening into the dwelling unit.